

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, VA 24504
Phone: (434) 455-3970

Addendum for Bid
Rivermont Avenue Bridge Repairs
2023-035

Date: December 28, 2022
From: Melissa Tillman, CPPB Contract Specialist
RE: Addendum No. 2

This Addendum becomes a part of the bidding documents and modifies the Project Manual and Drawing as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

1. **Question:** Are the superstructure embedded galvanic anodes slated to go in every concrete area? I.e. shotcrete, curb, sidewalk, etc. or the epoxy overlay?
Answer: Galvanic anodes shall be installed in deck patching, sidewalk curb repairs, sidewalk repairs, and shotcrete repairs. Galvanic anodes are not required in the epoxy overlay.
2. **Question:** Do we need any special permits for the flood plain/dam up the James River?
Answer: No.
3. **Question:** Where in the plans does it show where the concrete surface color coating work is supposed to be performed?
Answer: See Detail A and Notes on Sheet 6 of the project drawings.
4. **Question:** Is there anywhere in the plans that give a square footage of the structural steel to be painted?
Answer: No, As-Built Drawings are provided for your use. They are posted separately on the City's website at: www.lynchburgva.gov/current-solicitations due to the file size.
5. **Question:** What is the beam and diaphragm sizes?
Answer: Please refer to the above mentioned As-Built Drawings.

READ TERMS AND CONDITIONS AND SIGN

In compliance with the above BID, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____ E-mail: _____